

CLASS OF FIRE



Fires involving freely burning materials, e.g. Wood/ Textiles/ Paper	Fires involving Flammable liquids, E.g. Petrols and Spirits. NOT ALCOHOL OR COOKING OIL	Fires involving Flammable Gases E.g. Butane / Propane	Fires involving Flammable Metals E.g. Magnesium / Lithium	Fires involving Electrical equipment E.g. Photocopiers / Computers	Fires involving Cooking Oil & Fat E.g. Olive Oil / Maize Oil / Lard
--	---	---	---	--	---

TYPE OF EXTINGUISHER



Water					
Foam (AFFF)					
ABC Dry Powder					
Dry Special Powder					
CO 2 Gas					
Wet Chemical					

FIVE HANDY FIREWATCH TIPS

TO CARRY OUT AT LEAST MONTHLY !

- CHECK THAT ANTI-TAMPER TAG IS FITTED
- CHECK EXTINGUISHER IS STILL THE CORRECT TYPE FOR RISK PROTECTING
- CHECK THAT THE MOUNTING BRACKET IS SECURE
- IF A GAUGE IS FITTED - CHECK THAT IT SHOWS FULL
- CHECK THAT THE EXTINGUISHER HAS NOT BEEN DAMAGED/ DISCHARGED
- ENTER IN LOG BOOK

FIRE ALARM :-

Daily - Check panel - that the mains light is on & no other lights are lit or sounders operating

Weekly - Test a different call point , each week to ensure all are tested in rotation - **ENTER IN LOG BOOK**

EMERGENCY LIGHTS :-

Monthly - Switch off at mains or isolation switch, and check each light operates on standby power - **ENTER IN LOG BOOK**

Health & Safety (Safety Signs & Signals) Regulations 1996

MANDATORY "YOU MUST DO"	PROHIBITION "DO NOT"	HAZARD "DANGER"	FIRE FIGHTING EQUIPMENT	EMERGENCY ESCAPE ROUTES

CHECK :-

The sign is still valid to the location and is secure and in good condition

It is **your** duty to your employer & work colleagues to be vigilant and responsible for fire safety - if you have any concerns regarding fire safety in these premises contact:-

COMPANY FIRE WARDEN :